

Consumer Confidence Report reporting period 2010 date written 6/20/2011

Spanish (Espanol)

Este informe contiene informacion muy importante sobre la calidad de su agua potable. Por favor lea este informe o comuniquese con alguien que pueda traducir la informacion.

French (Francais)

Ce rapport contient des informations importantes sur votre eau potable. Traduisez-le ou parlez en avec quelqu'un qui le comprend bien.

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Clearwood is supplied with ground water from 3 well. Wells 1&2 are located on the hill at Beechside Dr in div #1, with Baldhill Rd behind them. The depth is approx 76 ft. Well #4 is located in the hole next to the ballfield on Bluehills Dr. The depth of this well is approx 45 ft. There are 2 large tanks outside the back gate Located on Weyerhauser's property. These tanks fill and gravity feed water from the wells to your house.

Source water assessment and its availability

Well #4 pumps sits at 45 ft deep in a hole surrounded by houses with septic tanks. Watching our nitrate levels is an important factor to the potential for contamination.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams,

ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

With Clearwood's wells being under 100 ft deep and more than 1040 septic systems in here, it is very important to have them pumped and inspected every 3 years. Think of it this way, what you and your neighbor put in the ground may contaminated the aquifers.

How can I get involved?

Clearwood has a water committee that meets on the 2nd Monday of every month, in the office @1:00 p.m. You are welcome to come join us. Watch for blue sandwich boards at front and back gate's for water information.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Clearwood water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EP A prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Range Your Low ! High Water			Sample Date	Violation	Typical Source
Inorganic Contaminants								
Nitrate [measured as Nitrogen] (ppm)	10	10	2.1	1.7	2.1	2010	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Asbestos (MFL)	7	7	0.128	NA		2010	No	Decay of asbestos cement water mains; Erosion of natural deposits
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceedinl: AL	Exceeds AL	Typical Source	
Inorganic Contaminants								
Lead - action level at COnSW1Jer taps (ppb)	0	15	0.001	2010	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Copper - action level at consumer taps (ppm)	1.3	1.3	0.24	2010	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Unit Descriptions

Term

Definition

ppm
ppb
MFL
NA
ND
NR

ppm: parts per million, or milligrams per liter (mg/L)
ppb: parts per billion, or micrograms per liter (µg/L)
MFL: million fibers per liter, used to measure asbestos concentration
NA: not applicable
ND: Not detected
NR: Monitoring not required, but recommended

Important Drinking Water Definitions

Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Julie Rhey-Baumann
Address: 21603 N Clearlake Blvd SE
Yelm, WA 98597
Phone: 360-894-4187
Fax: 360-894-2497
E-Mail: clearwoodwater@yahoo.com
Website: www.clearwood-yelm.com